A photograph of a city skyline at sunset, with the sun low on the horizon, casting a warm orange glow. The sky is filled with soft, wispy clouds. The city buildings are silhouetted against the bright sky. In the foreground, there is a body of water reflecting the colors of the sunset. A large, dark, semi-transparent circle is overlaid on the right side of the image, containing the text.

Architecture 2030 ZERO Code

Charles Eley, FAIA, PE
Architecture 2030 Senior Fellow

A photograph of a modern, multi-story building with a large, cantilevered roof structure. The building has a light-colored facade and large windows. The roof is made of a grid of white panels with small, square openings. The building is surrounded by lush green trees and a clear blue sky. The text "National and International ZERO Code" is overlaid on the image in white, and "Released April 2018" is overlaid in yellow.

National and International ZERO Code

Released April 2018


ZERO CODE™

Commercial • Institutional • Mid-Rise/High-Rise Residential Buildings

1 Design an energy efficient building


- Efficiency Standard: ASHRAE 90.1-2016 minimum;
ASHRAE 189.1-2017; others

- Efficient building envelope / daylighting
- Passive heating / cooling / ventilation
- Efficient systems / equipment / controls



2 Address the remaining building's energy needs with:

on-site
renewable
energy



and/or off-site
renewable
energy

wind • solar • hydro
(other non-CO₂ emitting sources)



zero-code.org

Source: Architecture 2030
Graphic adaptations: Sefaira; DOE



ZERO CODE™

Meeting the **ZERO CODE™**


Prescriptive Path

Requirements for minimum
building energy efficiency

- ☒ BUILDING ENVELOPE
- ☒ HVAC
- ☒ LIGHTING
- ☒ OTHER EQUIPMENT...

Performance Path

Modeled energy performance meets
or exceeds the minimum building
energy efficiency requirements



On-Site and/or Off-Site
Renewable Energy Required

<https://zero-code.org/energy-calculator/>

ABOUT YOUR BUILDING

Code Pathway: ☒ Prescriptive ☐ Performance

Country: United States *

State: Colorado *

City: Denver *

Number of Stories: 6 *

Add Another Use: *

Selected Use Type(s):
Office

OFFICE delete -

Gross Floor Area: 60000 * sq.ft *

GENERATE RESULTS →

ON-SITE PV SYSTEMS

Default Values estimate on-site building PV system potential. Uncheck Use Default Values to enter custom inputs. If your building has multiple PV systems, add them below. ⓘ

PV SYSTEM **Set Default Values** delete -

Estimated Area for Collectors: 7547.6 * sq.ft *

Module Type: Standard *

Losses (%): 10 *

Array Type: Fixed - Open Rack *

Tilt (Degrees): 10 *

Azimuth (Degrees): 180 *

Inverter Efficiency (%): 96 *

+ Add another PV System



RESULTS

☐ metric ☒ imperial

RENEWABLE ENERGY REQUIREMENTS


Energy Consumption & Generation

	kBtu/ft ² -yr	MBtu/yr
Estimated Building Energy Consumption	28.0	1,681.3
Total Renewable Energy Required	28.0	1,681.3
On-Site PV Generation Potential	9.0	540.4
Remaining Off-Site Procured Renewable Energy	19.0	1,140.9

On-Site PV System

Rated Capacity (kW)	105
Estimated Area for Collectors (ft ²)	7,548

ESTIMATED BUILDING ENERGY CONSUMPTION



Building Energy Consumption and End Uses are based on a **code compliant prototype building** modeled by Pacific Northwest National Laboratory. Actual building energy consumption will vary from modeled results.



ZERO Code & Technical Support Document downloads:



[Download the ZERO Code](#)





[Download the Technical Support Document](#)


A scenic view of the Golden Gate Bridge in San Francisco, California. The bridge's iconic red-orange towers and suspension cables are prominent against a backdrop of blue water and a sky with scattered white clouds. The bridge spans the Golden Gate Strait, connecting the city to Marin County. In the foreground, a rocky coastline with waves crashing against the shore is visible. The overall image has a slightly desaturated, artistic feel.

The ZERO Code for California

Minimum Energy Efficiency



Time-Dependent Source Energy



**Replaces TDV Energy
for the ZERO Code**



Off-Site Renewable Energy Procurement

Class One

- Self-Owned
- Community Solar
- Virtual PPA
- Renewable Energy Investment Trust

Class Two

- Direct Access to Wholesale Market
- Green Tariffs

Class Three

- Unbundled RECs



ZERO-Code.org Website

ABOUT YOUR BUILDING

Code Pathway:

☒ Prescriptive
 ☐ Performance

Country

United States

State

Colorado

City

Boulder

Number of Stories

3

Add Another Use

Selected Use Type(s):

Office

OFFICE

delete

Gross Floor Area

20000

sq.ft

ON-SITE PV SYSTEMS

Default values estimate on-site building PV system potential. Uncheck Use Default Values to enter custom inputs. If your building has multiple PV systems, add them below.

PV SYSTEM

Set Default Values

delete

Estimated Area for Collectors

4696.9

sq.ft

Module Type

Standard

Losses (%)

10

Array Type

Fixed - Open Rack

Tilt (Degrees)

10

Azimuth (Degrees)

180

Inverter Efficiency (%)

96

Add another PV System.

GENERATE RESULTS →

1.1.1. RESULTS

☐ metric ☒ imperial


- RENEWABLE ENERGY REQUIREMENTS

Energy Consumption & Generation	
	kBtu/yr
Estimated Building Energy Consumption	23.9
Total Renewable Energy Required	23.9
On-Site PV Generation Potential	16.6
Remaining Off-Site Procured Renewable Energy	11.2

On-site PV System

Rated Capacity (kW)	65
Estimated Area for Collectors (m ²)	4,696

ESTIMATED BUILDING ENERGY CONSUMPTION



Building Energy Consumption and End Uses are based on a code compliant prototype building modeled by Pacific Northwest National Laboratory. Actual building energy consumption will vary from modeled results.


Estimated Site EUI: 28.02 kWh/ft²-yr

Estimated Energy Consumption: 560.44 MWh/yr

End Use	Subtotal (kBtu/yr)	Percent
Heating	3.88	11.01%
Cooling	2.84	9.42%
Interior Lighting	5.48	19.50%
Plug Loads	10.79	38.50%
Service Hot Water	2.82	8.27%
Fans	2.70	9.62%
Other		
Collector Equipment	0.10	0.37%
Collector Light	0.90	3.22%
Pumps	0.80	0.00%
Total	28.02	100.00%

CBECC-Com Supports the ZERO Code

- PV Modeling Capabilities
- Battery Model
- Multiple Metrics including TDS
- ZERO Code Output Report (CSV)






The California Grid and Source Energy



Site Energy

British Thermal Unit (Btu)		kiloWatt-hour (kWh)		kiloJoule (kJ)
1 Btu	=	.000293 kWh	=	1.055 kJ
3,412 Btu	=	1 kWh	=	3,600 kJ
0.948 Btu	=	.000278 kWh	=	1 kJ

Source Energy




California BEES 1975-2005


- For three decades, California used a flat source energy multipliers:
 - 3.0 for electricity
(1 kWh = 10,236 Btu)
 - 1.0 for gas
(1 therm = 100,000 Btu)
- Replaced by time-dependent valued (TDV) energy in 2005









The California Grid and Source Energy



Installed Renewable Resources (as of 05/01/2018)



	Megawatts
 Solar	11,439
 Wind	6,295
 Small hydro	1,238
 Geothermal	1,790
 Biofuels	997
 Storage battery	134*
TOTAL	21,893

Source: CalISO.com

2017 Total System Electric Generation

Fuel Type	California In-State Generation (GWh)	Percent of California In-State Generation	Northwest Imports (GWh)	Southwest Imports (GWh)	California Energy Mix (GWh)	California Power Mix
Coal	302	0.15%	409	11,364	12,075	1.18%
Large Hydro	36,920	17.89%	4,531	1,536	42,987	14.72%
Natural Gas	89,564	43.40%	46	8,705	98,315	23.67%
Nuclear	17,925	8.69%	0	8,594	26,519	9.08%
Oil	33	0.02%	0	0	33	0.01%
Other	409	0.20%	0	0	409	0.14%
Renewables	61,183	29.65%	12,502	10,999	84,684	29.00%
Biomass	5,827	2.82%	1,015	32	6,874	2.35%
Geothermal	11,745	5.69%	23	937	12,705	4.35%
Small Hydro	6,413	3.11%	1,449	5	7,867	2.70%
Solar	24,331	11.79%	0	5,465	29,796	10.20%
Wind	12,867	6.24%	10,015	4,560	27,442	9.40%
Unspecified	N/A	N/A	22,385	4,632	27,017	9.25%
Total	206,336	100.00%	39,873	45,830	292,039	100.00%

Source: http://www.energy.ca.gov/almanac/electricity_data/total_system_power.html



Senate Bill 100
(recently signed by
Governor Brown)

33%
2020

50%
2026

60%
2030


100%
2045



2030 ZERO CODE™

Fossil Fuel Equivalency

Estimated U.S. Energy Consumption in 2017: 97.7 Quads



Source: LLNL April, 2018. Data is based on DOE/EIA MER (2017). If this information or a reproduction of it is used, credit must be given to the Lawrence Livermore National Laboratory and the Department of Energy, under whose auspices the work was performed. This chart was revised in 2017 to reflect changes made in mid-2016 to the Energy Information Administration's analysis methodology and reporting. The efficiency of electricity production is calculated as the total retail electricity delivered divided by the primary energy input into electricity generation. End use efficiency is estimated as 65% for the residential sector, 65% for the commercial sector, 21% for the transportation sector, and 49% for the industrial sector which was updated in 2017 to reflect DOE's analysis of manufacturing. Totals may not equal sum of components due to independent rounding. LLNL-MI-410527



Site Source Multipliers

Energy Type	Source Multiplier	Common Units	Site Btu / unit	Source Btu / unit
Imported Electricity	3.15	kWh	3,412	10,751
Exported Renewable Electricity	3.15	kWh	3,412	10,751
Natural Gas	1.09	Therms	100,000	109,000
Fuel Oil (1,2,4,5,6,Diesel, Kerosene)	1.19	Gallons	138,000	164,220
Propane & Liquid Propane	1.15	Gallons	91,000	104,650
Steam	1.45	lb	1,000	1,450
Hot Water	1.35	millions Btu	1,000,000	1,350,000
Chilled Water	1.04	millions Btu	1,000,000	1,040,000
Coal or Other	1.05	short ton	19,210,000	20,170,000

Notes: The Btu per lb of steam will vary depending on how much the steam is superheated.


Source: DOE Common Definition, ASHRAE Standard 105, ASHRAE Standard 189.1-2017 Addendum



Fossil Fuel Equivalency Approach

Primary Energy


~ 10,000 Btu



~ 10,000 Btu



~ 10,000 Btu



Electricity Production

1 kWh



1 kWh



1 kWh




- Source energy is unaffected as more clean generators are added to the grid.
- The source-site multiplier for wind, solar and other renewables is the same as fossil generators.

Captured Energy Approach


Primary Energy

3,412 Btu




1 kWh

3,412 Btu



1 kWh

3,412 Btu



1 kWh


Electricity Production

- Recommended by DOE.
- The source-site multiplier for wind, solar and other renewables is 1.0.

“Zero Heat Content” Approach

Primary Energy

ZERO Btu




1 kWh

ZERO Btu



1 kWh

ZERO Btu




1 kWh

Electricity Production


- Wind, solar and gravity are free.
- The source-site multiplier for wind, solar and other renewables is ZERO.
- Source energy and carbon emissions track each other exactly.



is Constantly Changing




The California Grid and Source Energy





Time Dependent Source (TDS) Energy

Application to Building Design



Time-Dependent Source Energy (kBtu/kWh)




SUNSHINE STATE


A close-up photograph of three young women wearing red and black 3D glasses, looking upwards with expressions of joy and anticipation. The woman on the left is smiling broadly, showing her teeth. The woman in the middle is also smiling, with her mouth slightly open. The woman on the right is smiling and looking up. They are all wearing 3D glasses with a red and black pattern. The background is a bright, hazy sky.

Patterns of TDS and Carbon Emissions are Identical


Time-Dependent Source Energy (kBtu/kWh)



Hourly Carbon Emissions (tons/kWh)




Simplified Visualization of the 8760 Time-Series




TDS vs. TDV – Week of March 23


TDS Energy (kBtu/kWh)




TDV Energy (kBtu/kWh)



TDS vs. TDV – Climate Zone 3




TDS




TDV

TDS vs. TDV – Climate Zone 10




TDS




TDV


TDS vs. TDV – Climate Zone 12



TDS



TDV




Source Energy Factors


Sources of Off-Site Renewable Energy




Source Energy Factors




Hourly Time Dependent Carbon – NonRes – 15 years



2012 Solar Production – NP15 Trading Hub



2012 Wind Production – NP15 Trading Hub



Source Energy Factors for On-Site PV

Climate Zone	Source Energy Factor	Climate Zone	Source Energy Factor
1	3,296	9	3,319
2	3,330	10	3,295
3	3,322	11	3,322
4	3,322	12	3,287
5	3,293	13	3,274
6	3,260	14	3,292
7	3,277	15	3,304
8	3,307	16	3,344



Source Energy Factors for Off-Site Procurement

	Avoided Source Energy (Btu/kWh)	Avoided Emissions (lb/MWh)	Avoided TDV Energy (kBtu/kWh)
Wind	5,374	650	28.06
Solar	3,542	429	27.77
Geothermal	5,190	628	27.57
Hydro	5,190	628	27.57

The values for wind and solar are based on the average of power procured through the NP-15 and SP-15 trading hubs for 2012. Annual average values are used for geothermal and hydro.

Source: Table 5, TSD for the ZERO Code for California



Off-Site Renewable Energy Procurement


A photograph of a large-scale solar farm. In the foreground, a single solar panel is shown in detail, tilted at an angle. It is a monocrystalline or polycrystalline silicon panel with a grid of cells. Below the panel, the metal support structure is visible. In the background, many more panels are arranged in long, straight rows, stretching across a dry, yellowish-brown field. The sky is a clear, bright blue with a few wispy white clouds on the right side. The overall scene conveys a sense of clean, renewable energy production in a rural or undeveloped area.

Net Metering

PV system is located behind the meter, a common arrangement for small and medium sized buildings

Customer pays for the net energy that is used, e.g. delivered electricity minus exported electricity


Meter can “run backwards”



Separate Meter for PV System

Renewable energy system is on a separate meter and the owner is compensated through a feed-in tariff

Common arrangement for direct PPAs and larger systems




Off-Site Renewable Energy

Energy already flows through the grid

Renewable energy system supplies the grid from a remote location

Renewable energy credits assign production to the building

Economies of scale can be achieved



Off-Site Renewable Energy Procurement Options

Class One

- Self-Owned
- Community Solar
- Virtual PPA
- Renewable Energy Investment Trust

- ❑ High probability of additionality
- ❑ Long-term commitment

Class Two

- Direct Access to Wholesale Market
- Green Tariffs

- ❑ Medium probability of additionality
- ❑ Customers can easily opt out

Class Three

- Unbundled RECs

- ❑ Little chance of additionality
- ❑ Least desirable option

See TSD at zero-code.org for more details

Evaluation Criteria for Off-Site Systems

- Additionality
- Long-Term Commitment
- Renewable Energy Generation Source
- Assignment to ZNC Building
- Grid Management Capability
- Environmental Impact
- Inspirational/Educational Value
- Incremental Acquisition
- Permanent Financing

Most Important



Least Important

Renewable Energy Procurement Factors

			Class 1				Class 2		Class 3
	Weight	Class 1	Self-Owned Off-Site	Community Renewable Sales	Virtual PPA	REIFs	Direct Access	Green Retail Tariffs	Unbundled RECs
Considerations									
Inspirational/Educational Value	6%	High	Medium	Medium	Low	Zero	Low	Low	Low
Probability of Additionality	30%	High	Medium	Medium	Medium	Zero	Low	Low	Zero
Long-Term Commitment	24%	Yes	Possible	Possible	Difficult	No	Possible	Difficult	Difficult
Permanent Financing	3%	Yes	Possible	Possible	Unlikely	No	No	No	No
Environmental Impact	6%	Low	Depends	Depends	Depends	Depends	Depends	Depends	Depends
Incremental Acquisition	6%	Yes	Yes	Possible	Difficult	No	No	Yes	Yes
Assignment to ZNC Building	12%	Yes	Possible	Possible	Difficult	No	Difficult	Yes	No
Grid Management Capability	2%	Possible	Possible	Possible	Difficult	No	Yes	Yes	No
Renewable Generation Source	24%	Qualifying	Qualifying	Qualifying	Some RECs	All RECs	Some RECs	Some RECs	All RECs
	100%		3	2	1	0			
			Good			Bad			
Calculation of Coefficients									
Inspirational/Educational Value	3		2	2	1	1	1	1	1
Probability of Additionality	3		2	2	2	2	1	1	0
Long-Term Commitment	3		2	2	3	3	2	1	1
Permanent Financing	3		2	1	2	2	0	0	0
Environmental Impact	3		2	2	2	2	2	2	2
Incremental Acquisition	3		3	3	2	3	0	3	3
Assignment to ZNC Building	3		2	3	2	2	1	3	0
Grid Management Capability	2		2	3	2	2	3	3	0
Renewable Generation Source	3		3	3	3	3	1	1	0
Sumproduct	3.61		2.79	3.00	2.91	2.97	1.70	1.88	0.61
Calculated Coefficient	1.00		0.77	0.83	0.81	0.82	0.47	0.52	0.17
Average for Class			0.81				0.50		0.17
Recommended for Class			0.80				0.50		0.20



Minimum Requirements

- Legally binding contract to procure qualifying off-site renewable energy.
- Contract shall have duration of not less than 15 years
- RECs and other environmental attributes associated with the procured off-site renewable energy shall be assigned to the building project
- The renewable energy generating source shall be photovoltaic systems, solar thermal power plants, geothermal power plants, wind turbines or eligible hydro.
- The generation source shall be located where the energy can be delivered to the building site (probably within CalSO)
- The off-site renewable energy producer shall maintain transparent accounting that clearly assigns production to the ZNC building



Procurement Factors

Class	Procurement Factor (PF)	Procurement Method	Additional Requirements
1	0.75	Community Solar	
		REIFs	Entity must be managed to prevent fraud or misuse of funds.
		Virtual PPA	
		Self-Owned Off-Site	Provisions shall prevent the generation asset from being sold separately from the building.
2	0.55	Green Retail Tariffs	The offering shall not include the purchase of unbundled RECs.
		Direct Access	The offering shall not include the purchase of unbundled RECs.
3	0.20	Unbundled RECs	The vintage of the RECs shall align with building energy use.

Avoided Source Energy from Off-Site Procurement

$$\text{Avoided Source Energy} = \text{Procured Off-Site Renewable Energy} \times \text{Source Energy Factor} \times \text{Procurement Factor}$$

Amount
purchased
through vPPA
or other means

(kWh)

Depends on
generation
source

(Btu/kWh)

Depends on
procurement
method

(unitless)





Batteries and Storage



Mira Loma Battery Storage Facility



Batteries Behind the Meter




Comparison of Metrics with Regard to Batteries

	Site Energy (kBtu/ft ² /y)	Time-Dependent Source (TDS) Energy (kBtu/ft ² -y)	Carbon Emissions (lb/ft ² -y)	Time-Dependent Valued (TDV) Energy (kBtu/ft ² -y)
Building Energy Use				
Electricity	25.90	29.46	3.80	217.28
Gas	5.83	5.83	0.75	12.32
Total	31.72	35.29	4.55	229.60
On-Site PV System				
Production	-25.90	-19.32	-2.49	-184.40
Battery				
Charging	8.02	5.79	0.70	54.82
Discharging	-7.22	-15.35	-1.86	-77.42
Net (battery alone)	0.80	-9.55	-1.16	-22.60
Summary				
Net (without battery)	5.83	15.04	1.87	45.20
Net (with battery)	6.63	5.49	0.71	22.28
Battery Benefit	14%	-64%	-62%	-50%




Thermal Mass in Envelope




Building Mass

Thermal Storage Revisited




Thermal Storage



CBECC-Com Battery Control Strategies

- Basic
- Time of Use
- Advanced DR Control (TDV)
- Advanced DR Control (TDS)



The ZERO Code Energy Calculator

ABOUT YOUR BUILDING

Code Pathway: ☒ Prescriptive ☐ Performance

Country: United States

State: Colorado

City: Boulder

Number of Stories: 3

Add another Use

Selected Use Type: Office

OFFICE

Floor Area: 10000 sq.ft

delete

ON-SITE PV SYSTEMS

Default Values estimate on-site building PV system potential. Uncheck Use Default Values to enter custom inputs. If your building has multiple PV systems, add them below.

PV SYSTEM Set Default Values delete

Estimated Area for Collectors: 4696.9 sq.ft

Module Type: Standard

Losses (%): 10

Array Type: Fixed - Open Rack

Tilt (Degrees): 10

Azimuth (Degrees): 180

Inverter Efficiency (%): 96

☒ Add another PV System

GENERATE RESULTS →


RESULTS

☐ metric ☒ imperial

RENEWABLE ENERGY REQUIREMENTS

Energy Consumption & Generation		
	kBtu/ft ² -yr	MBtu/yr
Estimated Building Energy Consumption	28.0	680.4
Total Renewable Energy Required	28.0	680.4
On-Site PV Generation Potential	16.8	336.2
Remaining Off-Site Procured Renewable Energy	11.2	224.2
On-Site PV System		
Rated Capacity (kW)		65
Estimated Area for Collectors (ft ²)		4,696

ESTIMATED BUILDING ENERGY CONSUMPTION



Estimated Site EUI: 28.02 kBtu/ft²-yr

Estimated Energy Consumption: 560.44 MBtu/yr

End Use	Subtotal (kBtu/ft ² -yr)	Percent
Heating	3.08	11.01%
Cooling	2.84	9.42%
Interior Lighting	5.48	19.50%
Plug Loads	10.79	38.50%
Service Hot Water	2.82	8.27%
Fans	2.70	9.62%
Other	0.80	2.85%
Collector Equipment	0.10	0.37%
Collector Light	0.30	1.12%
Pumps	0.80	2.85%
Total	28.02	100.00%

The ZERO Code Energy Calculator

ABOUT YOUR BUILDING

Code Pathway: ☒ Prescriptive ☐ Performance

Climate Zone ⁱ 3 *

Number of Stories 2 *

Add Another Use *

Selected Use Type(s):

School *

SCHOOL delete -

Gross Floor Area (sq.ft) 50000 *

ON-SITE PV SYSTEMS

Default Values estimate on-site building PV system potential. Uncheck Use Default Values to enter custom inputs. If your building has multiple PV systems, add them below. ⁱ

PV SYSTEM

Set Default Values

delete -

Estimated Area for Collectors 21022.3 * sq.ft *

Module Type Standard *


Losses (%) 10 *

Array Type Fixed - Open Rack *

Tilt (Degrees) 10 *

Azimuth (Degrees) 180 *

Inverter Efficiency (%) 96 *

 Add another PV System

RESULTS

← ENTER BUILDING AND PV INFORMATION TO THE LEFT TO GENERATE REQUIREMENTS FOR REACHING ZERO NET CARBON

GENERATE RESULTS →

The ZERO Code Energy Calculator



ABOUT YOUR BUILDING

Code Pathway:

☒ Prescriptive ☐ Performance

Climate Zone ⁱ

3

Number of Stories

2

Add Another Use

Selected Use Type(s):

School

SCHOOL

delete

Gross Floor Area (sq.ft)

50000



ON-SITE PV SYSTEMS

Default Values estimate on-site building PV system potential. Uncheck Use Default Values to enter custom inputs. If your building has multiple PV systems, add them below. ⁱ

PV SYSTEM

Set Default Values

delete

Estimated Area for Collectors

21022.3

sq.ft

Module Type

Standard

Losses (%)

10

Array Type

Fixed - Open Rack

Tilt (Degrees)

10

Azimuth (Degrees)

180

Inverter Efficiency (%)

96

+ Add another PV System



RESULTS

RENEWABLE ENERGY REQUIREMENTS


Energy Consumption & Generation

	kBtu/ft ² -yr	MBtu/yr
Estimated Building Source Energy Consumption	32.8	1,642.1
Total Renewable Energy Required	32.8	1,642.1
On-Site PV Generation Potential	22.2	1,110.6
Remaining Off-Site Procured Renewable Energy	10.6	531.5

On-Site PV System

Rated Capacity (kW)	293
Estimated Area for Collectors (ft ²)	21,022

ESTIMATED BUILDING ENERGY IMPACTS



Building Energy Impacts and End Uses are based on code compliant prototype buildings modeled by NORESO in their Impact Analysis. Actual building energy consumption will vary from modeled results.

The ZERO Code Energy Calculator

GENERATE RESULTS →

Estimated Source EUI: **32.84** kBtu/ft²-yr

Estimated Source Energy Consumption: **1,642.09** MBtu/yr

End Use	Subtotal (kBtu/ft ² -yr)	Percent
Heating	7.87	23.97%
Cooling	1.35	4.10%
Interior Lighting	4.15	12.65%
Plug Loads	8.25	25.13%
Service Hot Water	5.85	17.80%
Fans	4.29	13.07%
Other		
Exterior Light	0.66	2.00%
Heat Rejection	0.03	0.09%
Pumps	0.39	1.19%
Total	32.84	100.00%

▼ PVWATTS RESULTS

ANNUAL AC & DC PRODUCTION





Wrapup

The ZERO Code for California:

- Builds on the adopted 2019 California Building Energy Efficiency Standards, the global energy efficiency benchmark for commercial, institutional and mid- to high-rise residential buildings
- Supplements the energy efficiency requirements of the California BEES by requiring that on-site renewable energy systems be installed or off-site renewable energy be procured such that ZERO Code compliant buildings result in zero net carbon emissions on an annual basis
- Represents a paradigm shift in building codes to directly address climate change by using hourly source energy / carbon emissions as the metric for building performance
- Sets a framework for addressing tall and energy intensive buildings
- Is flexible, impactful, performance-based, and harmonious with the renewables-rich California electric grid
- Easily adoptable by local governments as a reach standard
- Encourages:
 - Even greater energy efficiency than required by the California BEES
 - Storage technologies to shift load to periods when grid carbon emissions are low
 - On-site renewable energy systems when feasible



More Reading

ZERO CODE™

HOME ABOUT ZERO CODE ENERGY CALCULATORS CONTACT Q


ZERO Code & Technical Support Document:

Access ASHRAE 90.1-2016



ZERO Code for California & Technical Support Document for California:

Access 2019 California BEES



ZERO Code Energy Calculators

The ZERO Code is supported by **Energy Calculators** that eases the implementation process and reduces errors when applying the prescriptive compliance path of ASHRAE 90.1-2016 or 2019 California Building Energy Efficiency Standards (BEES). An Application Program Interface (API) for the national and international ZERO Code Energy Calculator has been developed so that users can interact in a programmatic way with the software, enabling its implementation as a website or application for smart phones and tablets. Ultimately this approach will save years and valuable resources that would otherwise be spent on developing new compliance tools and mechanisms.

The ZERO Code Energy Calculator API is free and open source. For access to the ZERO Code Energy Calculator API documentation, or for information about incorporating the International Green Construction Code (IgCC), ASHRAE Standard 189.1-2017 or other building energy standard, please contact Architecture 2030 at info@architecture2030.org.



<https://zero-code.org/zero-code/>